


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm		
NAME: LED Ceiling light	TYPE:N/A	WEIGHT:N/A
SPEC.:N/A	DIM.: N/A	SERIAL No.:N/A
MFR.: Maxim	SUR.:N/A	Shielding Angle:N/A

DATA OF LAMP		PHOTOMETRIC DATA Eff: 81.10 lm/W			
MODEL	RSZ200424502-10	I _{max} (cd)	247.8	S/MH(C0/180)	1.35
NOMINAL POWER(W)		LOR(%)	100.0	S/MH(C90/270)	1.37
RATED VOLTAGE(V)	120	TOTAL FLUX(lm)	965.15	η UP,DN(C0-180)	0.1,50.1
NOMINAL FLUX(lm)	965.145	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,49.8
LAMPS INSIDE	1	η up(%)	0.1	CIBSE SHR NOM	1.50
TEST VOLTAGE(V)	120	η down(%)	99.9	CIBSE SHR MAX	1.55

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: 10.0deg/s
 Temperature:24.9DEG
 Operators:East
 Test Date:2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
 Humidity:51%
 Test Distance:2.502m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	245.5	245.1	244.6	244.2	244.2	244.7	245.2	245.5	0- 10	23.50	23.50	2.44, 2.44
20	238.8	237.8	236.8	236.4	236.3	237.1	238.2	238.9	10- 20	68.37	91.88	9.52, 9.52
30	227.7	226.2	224.9	224.2	224.1	225.1	226.8	227.7	20- 30	107.3	199.1	20.6, 20.6
40	212.2	210.3	208.8	208.0	207.8	209.2	211.1	212.6	30- 40	136.9	336.1	34.8, 34.8
50	191.9	189.9	188.2	187.4	186.8	188.1	190.3	192.0	40- 50	154.8	490.8	50.9, 50.9
60	165.6	163.6	162.1	161.2	160.3	161.5	163.9	165.7	50- 60	158.2	649.0	67.2, 67.2
70	134.8	132.9	131.6	130.9	128.9	129.9	132.0	134.0	60- 70	146.6	795.6	82.4, 82.4
80	95.09	93.84	92.48	90.99	88.13	88.31	90.57	93.34	70- 80	120.0	915.6	94.9, 94.9
90	0.2864	3.392	2.754	0.1372	0.0352	0.0358	0.0350	0.0553	80- 90	48.64	964.2	99.9, 99.9
100	0.1091	0.1080	0.1109	0.1118	0.0551	0.0550	0.0520	0.0508	90-100	0.1245	964.3	99.9, 99.9
110	0.1107	0.1091	0.1153	0.1155	0.0836	0.0809	0.0805	0.0762	100-110	0.0948	964.4	99.9, 99.9
120	0.1280	0.1181	0.1243	0.1291	0.1170	0.1063	0.1046	0.1019	110-120	0.1039	964.5	99.9, 99.9
130	0.1621	0.1569	0.1651	0.1679	0.1377	0.1303	0.1250	0.1240	120-130	0.1169	964.6	99.9, 99.9
140	0.2278	0.2387	0.2418	0.2423	0.1457	0.1433	0.1404	0.1369	130-140	0.1281	964.8	100, 100
150	0.3137	0.3406	0.3419	0.3387	0.1524	0.1558	0.1534	0.1487	140-150	0.1361	964.9	100, 100
160	0.3837	0.3879	0.3932	0.3990	0.1927	0.1900	0.1869	0.1765	150-160	0.1241	965.0	100, 100
170	0.3589	0.3531	0.3552	0.3651	0.2299	0.2192	0.2151	0.2127	160-170	0.0830	965.1	100, 100
180	0.3016	0.2816	0.2770	0.3017	0.3044	0.2949	0.2781	0.2862	170-180	0.0278	965.1	100, 100
DEG	LUMINOUS INTENSITY:cd Less than 25% Percent = 11.7 %									UNIT:lm		

Conical surface Flux(90deg): 412.06 lm

%lum = 42.7%

%lamp = 42.7%

Conical surface Flux(120deg): 649.04 lm

%lum = 67.2%


%lamp = 67.2%

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: 10.0deg/s
 Temperature: 24.9DEG
 Operators: East
 Test Date: 2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.351
 Humidity: 51%
 Test Distance: 2.502m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm		
NAME: LED Ceiling light	TYPE:N/A	WEIGHT:N/A
SPEC.:N/A	DIM.: N/A	SERIAL No.:N/A
MFR.: Maxim	SUR.:N/A	Shielding Angle:N/A



LUMINANCE cd/(m2)		
G(DEG)	C0/180	C90/270
85	47979	46739
80	44653	43427
75	36965	36026
70	32135	31376
65	29079	28419
60	27002	26430
55	25500	24983
50	24343	23874
45	23387	22966


C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: 10.0deg/s
Temperature:24.9DEG
Operators:East
Test Date:2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
Humidity:51%
Test Distance:2.502m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm		
NAME: LED Ceiling light	TYPE:N/A	WEIGHT:N/A
SPEC.:N/A	DIM.: N/A	SERIAL No.:N/A
MFR.: Maxim	SUR.:N/A	Shielding Angle:N/A

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	.00
1.0	1.00	.95	.90	.98	.93	.89	.93	.89	.86	.89	.86	.83	.86	.83	.81	.78
2.0	.85	.77	.70	.83	.76	.70	.80	.73	.68	.76	.71	.66	.73	.69	.65	.62
3.0	.74	.64	.57	.72	.63	.56	.69	.61	.55	.66	.60	.54	.63	.58	.53	.51
4.0	.64	.55	.47	.63	.54	.47	.60	.52	.46	.58	.51	.45	.56	.50	.45	.42
5.0	.57	.47	.40	.56	.46	.40	.54	.45	.39	.51	.44	.39	.50	.43	.38	.36
6.0	.51	.41	.34	.50	.41	.34	.48	.40	.34	.46	.39	.33	.45	.38	.33	.31
7.0	.46	.37	.30	.45	.36	.30	.43	.35	.29	.42	.35	.29	.41	.34	.29	.27
8.0	.42	.33	.26	.41	.32	.26	.40	.32	.26	.38	.31	.26	.37	.31	.26	.24
9.0	.38	.29	.24	.38	.29	.23	.36	.29	.23	.35	.28	.23	.34	.28	.23	.21
10.0	.35	.27	.21	.35	.27	.21	.34	.26	.21	.33	.26	.21	.32	.25	.21	.19



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: 10.0deg/s
 Temperature:24.9DEG
 Operators:East
 Test Date:2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
 Humidity:51%
 Test Distance:2.502m [K=1.0000]
 Remarks:

WEC AND CCEC

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm								
NAME: LED Ceiling light				TYPE:N/A			WEIGHT:N/A	
SPEC.:N/A				DIM.: N/A			SERIAL No.:N/A	
MFR.: Maxim				SUR.:N/A			Shielding Angle:N/A	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.380	.216	.068	.373	.213	.068	.359	.206	.066	.347	.200	.064	.335	.194	.063	
2.0	.341	.187	.057	.335	.184	.057	.323	.179	.056	.311	.175	.055	.301	.170	.054	
3.0	.307	.163	.049	.301	.161	.049	.290	.157	.048	.280	.154	.047	.271	.150	.046	
4.0	.277	.144	.042	.272	.142	.042	.263	.139	.042	.254	.136	.041	.245	.133	.041	
5.0	.252	.129	.037	.248	.127	.037	.239	.125	.037	.231	.122	.036	.224	.120	.036	
6.0	.231	.116	.033	.227	.115	.033	.220	.113	.033	.213	.110	.032	.206	.108	.032	
7.0	.213	.105	.030	.210	.104	.030	.203	.103	.030	.197	.101	.029	.191	.099	.029	
8.0	.198	.097	.027	.194	.096	.027	.188	.094	.027	.183	.093	.027	.177	.091	.027	
9.0	.184	.089	.025	.181	.088	.025	.176	.087	.025	.171	.086	.024	.166	.084	.024	
10.0	.172	.083	.023	.170	.082	.023	.165	.081	.023	.160	.079	.023	.156	.078	.022	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.191	.191	.191	.163	.163	.163	.112	.112	.112	.064	.064	.064	.020	.020	.020	
1.0	.186	.156	.130	.159	.134	.111	.109	.092	.077	.063	.053	.045	.020	.017	.015	
2.0	.180	.132	.093	.154	.114	.080	.105	.079	.056	.061	.046	.033	.020	.015	.011	
3.0	.172	.115	.070	.148	.099	.061	.101	.069	.042	.059	.040	.025	.019	.013	.008	
4.0	.165	.102	.055	.141	.088	.048	.097	.062	.034	.056	.036	.020	.018	.012	.007	
5.0	.157	.092	.045	.135	.080	.039	.093	.056	.027	.054	.033	.016	.017	.011	.005	
6.0	.149	.084	.037	.128	.073	.033	.088	.051	.023	.051	.030	.014	.017	.010	.005	
7.0	.142	.077	.032	.122	.067	.028	.084	.047	.020	.049	.028	.012	.016	.009	.004	
8.0	.135	.071	.028	.116	.062	.024	.080	.043	.017	.047	.026	.010	.015	.008	.003	
9.0	.128	.066	.025	.110	.058	.022	.076	.041	.015	.045	.024	.009	.014	.008	.003	
10.0	.122	.062	.022	.105	.054	.019	.073	.038	.014	.043	.022	.008	.014	.007	.003	

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: 10.0deg/s
 Temperature:24.9DEG
 Operators:East
 Test Date:2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
 Humidity:51%
 Test Distance:2.502m [K=1.0000]
 Remarks:

UGR(Unified Glare Rating) Table

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm											
NAME: LED Ceiling light					TYPE:N/A			WEIGHT:N/A			
SPEC.:N/A					DIM.: N/A			SERIAL No.:N/A			
MFR.: Maxim					SUR.:N/A			Shielding Angle:N/A			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H		24.3	26.0	24.6	26.2	26.4	24.2	25.9	24.5	26.1	26.3
3H		26.7	28.3	27.0	28.5	28.8	26.6	28.2	26.9	28.4	28.7
4H		28.0	29.5	28.3	29.7	30.0	27.9	29.3	28.2	29.6	29.9
6H		29.2	30.6	29.6	30.9	31.2	29.1	30.5	29.4	30.8	31.1
8H		29.8	31.1	30.1	31.4	31.7	29.6	31.0	30.0	31.3	31.6
12H		30.2	31.5	30.6	31.8	32.2	30.1	31.4	30.4	31.7	32.0
4H	2H	25.2	26.7	25.5	26.9	27.2	25.1	26.6	25.4	26.9	27.1
	3H	27.8	29.1	28.1	29.4	29.7	27.7	29.0	28.1	29.3	29.6
	4H	29.2	30.4	29.6	30.7	31.1	29.1	30.3	29.5	30.6	31.0
	6H	30.6	31.7	31.0	32.1	32.4	30.5	31.6	30.9	31.9	32.3
	8H	31.3	32.3	31.7	32.7	33.1	31.1	32.2	31.6	32.5	32.9
8H	12H	31.8	32.7	32.2	33.1	33.5	31.6	32.6	32.1	33.0	33.4
	4H	29.7	30.8	30.2	31.1	31.5	29.7	30.7	30.1	31.1	31.5
	6H	31.4	32.3	31.9	32.7	33.1	31.3	32.2	31.8	32.6	33.0
	8H	32.2	33.0	32.7	33.4	33.9	32.1	32.9	32.6	33.3	33.8
	12H	32.9	33.6	33.4	34.0	34.5	32.8	33.4	33.2	33.9	34.4
12H	4H	29.8	30.8	30.3	31.2	31.6	29.8	30.7	30.2	31.1	31.5
	6H	31.6	32.4	32.1	32.8	33.3	31.5	32.3	32.0	32.7	33.2
	8H	32.5	33.2	33.0	33.6	34.1	32.4	33.1	32.9	33.5	34.0
Variations with the observer position at spacings:											
S = 1.0H		+ 0.1 / - 0.1					+ 0.1 / - 0.1				
1.5H		+ 0.2 / - 0.2					+ 0.2 / - 0.3				
2.0H		+ 0.2 / - 0.3					+ 0.2 / - 0.3				

CIE Pub.117 Corrected 965.1 lm Total Lamp Luminous Flux.(8log(F/F0) = -0.1)

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: 10.0deg/s
Temperature:24.9DEG
Operators:East
Test Date:2020-04-27

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
Humidity:51%
Test Distance:2.502m [K=1.0000]
Remarks:


```

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
Humidity:51%
Test Distance:2.502m [K=1.0000]
Remarks:

```

ISOCANDELA DIAGRAM

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm		
NAME: LED Ceiling light	TYPE:N/A	WEIGHT:N/A
SPEC.:N/A	DIM.: N/A	SERIAL No.:N/A
MFR.: Maxim	SUR.:N/A	Shielding Angle:N/A




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: 10.0deg/s
Temperature: 24.9DEG
Operators: East
Test Date: 2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.351
Humidity: 51%
Test Distance: 2.502m [K=1.0000]
Remarks:

AAI Figure

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm		
NAME: LED Ceiling light	TYPE:N/A	WEIGHT:N/A
SPEC.:N/A	DIM.: N/A	SERIAL No.:N/A
MFR.: Maxim	SUR.:N/A	Shielding Angle:N/A

Flux out:835.2 lm




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: 10.0deg/s
 Temperature: 24.9DEG
 Operators: East
 Test Date: 2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.351
 Humidity: 51%
 Test Distance: 2.502m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm		
NAME: LED Ceiling light	TYPE:N/A	WEIGHT:N/A
SPEC.:N/A	DIM.: N/A	SERIAL No.:N/A
MFR.: Maxim	SUR.:N/A	Shielding Angle:N/A



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: 10.0deg/s
 Temperature:24.9DEG
 Operators:East
 Test Date:2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
 Humidity:51%
 Test Distance:2.502m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm		
NAME: LED Ceiling light	TYPE:N/A	WEIGHT:N/A
SPEC.:N/A	DIM.: N/A	SERIAL No.:N/A
MFR.: Maxim	SUR.:N/A	Shielding Angle:N/A


AvgL	cd/m2
L_0~180(65)av	28576
L_0~180(75)av	36036
L_0~180(85)av	43107
L_90~270(65)av	28565
L_90~270(75)av	36000
L_90~270(85)av	43166
L_45(65)av	28586
L_45(75)av	36046
L_45(85)av	43017

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: 10.0deg/s
 Temperature:24.9DEG
 Operators:East
 Test Date:2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
 Humidity:51%
 Test Distance:2.502m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: 10.0deg/s
Temperature: 24.9DEG
Operators: East
Test Date: 2020-04-27

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-R5000_V2 SYSTEM V2.0.351
Humidity: 51%
Test Distance: 2.502m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:120.0V I:0.1000A P:11.90W PF:0.9918 Lamp Flux:965.145x1 lm		
NAME: LED Ceiling light	TYPE:N/A	WEIGHT:N/A
SPEC.:N/A	DIM.: N/A	SERIAL No.:N/A
MFR.: Maxim	SUR.:N/A	Shielding Angle:N/A

Table--1

UNIT: cd

C(DEC)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
γ (DEC)	0	248	248	248	248	248	248	248	248	248	248	248	248	248	248	248			
5	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247			
10	246	245	245	245	245	244	244	244	244	244	245	245	245	245	246	246			
15	243	242	242	242	241	241	241	241	241	241	242	242	242	243	243	243			
20	239	238	238	237	237	237	236	236	236	237	237	238	238	239	239	239			
25	234	233	233	232	231	231	231	231	231	231	232	232	233	234	234	234			
30	228	227	226	225	225	225	224	224	224	225	225	226	227	227	228	228			
35	220	220	219	218	217	217	217	217	216	217	218	219	219	220	221	221			
40	212	211	210	209	209	208	208	208	208	208	209	210	211	212	213	213			
45	203	202	201	200	199	199	198	198	198	199	199	200	201	203	203	203			
50	192	191	190	189	188	188	187	187	187	187	188	189	190	191	192	192			
55	179	178	177	177	176	175	175	175	174	174	175	177	178	179	179	180			
60	166	165	164	163	162	162	161	161	160	161	161	163	164	165	166	166			
65	151	150	149	148	147	147	146	146	146	146	147	148	149	150	151	151			
70	135	134	133	132	132	131	131	131	129	129	130	131	132	133	134	134			
75	117	116	116	115	114	114	114	113	111	111	112	113	114	115	116	117			
80	95.1	94.6	93.8	93.2	92.5	91.8	91.0	90.0	88.1	88.0	88.3	89.2	90.6	92.1	93.3	94.2			
85	51.3	52.0	52.0	51.1	50.0	48.7	44.9	42.5	40.9	39.8	39.6	40.4	42.3	44.7	47.4	49.9			
90	0.29	3.20	3.39	3.14	2.75	0.17	0.14	0.14	0.04	0.04	0.04	0.04	0.04	0.04	0.06	0.12			
95	0.10	0.10	0.10	0.10	0.10	0.10	0.11	0.11	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04			
100	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.06	0.05	0.06	0.05	0.05	0.05	0.05	0.05			
105	0.11	0.11	0.11	0.11	0.11	0.11	0.12	0.11	0.07	0.07	0.07	0.07	0.07	0.07	0.06	0.07			
110	0.11	0.11	0.11	0.11	0.12	0.12	0.12	0.11	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08			
115	0.12	0.11	0.11	0.11	0.12	0.12	0.12	0.12	0.10	0.09	0.09	0.09	0.09	0.09	0.09	0.09			
120	0.13	0.12	0.12	0.12	0.12	0.13	0.13	0.13	0.12	0.11	0.11	0.11	0.10	0.10	0.10	0.10			
125	0.14	0.14	0.14	0.14	0.14	0.14	0.15	0.14	0.13	0.13	0.12	0.12	0.12	0.12	0.12	0.12			
130	0.16	0.16	0.16	0.16	0.17	0.17	0.17	0.16	0.14	0.13	0.13	0.13	0.12	0.13	0.12	0.13			
135	0.19	0.19	0.19	0.19	0.20	0.20	0.20	0.19	0.14	0.14	0.14	0.14	0.14	0.13	0.13	0.14			
140	0.23	0.23	0.24	0.24	0.24	0.24	0.24	0.23	0.15	0.14	0.14	0.14	0.14	0.14	0.14	0.14			
145	0.27	0.28	0.30	0.30	0.30	0.30	0.29	0.28	0.15	0.14	0.15	0.15	0.15	0.15	0.14	0.15			
150	0.31	0.33	0.34	0.34	0.34	0.35	0.34	0.32	0.15	0.15	0.16	0.15	0.15	0.15	0.15	0.16			
155	0.36	0.37	0.37	0.37	0.38	0.38	0.38	0.37	0.17	0.16	0.17	0.17	0.17	0.17	0.16	0.18			
160	0.38	0.39	0.39	0.40	0.39	0.40	0.40	0.39	0.19	0.19	0.19	0.19	0.19	0.18	0.18	0.20			
165	0.38	0.38	0.38	0.38	0.39	0.39	0.39	0.38	0.21	0.21	0.20	0.20	0.20	0.20	0.19	0.21			
170	0.36	0.35	0.35	0.35	0.36	0.36	0.37	0.36	0.23	0.23	0.22	0.22	0.22	0.21	0.21	0.23			
175	0.35	0.34	0.33	0.32	0.32	0.33	0.34	0.35	0.27	0.27	0.26	0.25	0.25	0.24	0.25	0.27			
180	0.30	0.29	0.28	0.28	0.28	0.29	0.30	0.31	0.30	0.31	0.29	0.29	0.28	0.28	0.29	0.30			

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: 10.0deg/s
Temperature:24.9DEG
Operators:East
Test Date:2020-04-27

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-R5000_V2 SYSTEM V2.0.351
Humidity:51%
Test Distance:2.502m [K=1.0000]
Remarks: